

and Report

CONDITIONS OF ACCEPTABILITY:

1. The devices have been tested at output side of a drive with an output frequency of 60 Hz and a carrier frequency of about 4 kHz.
2. The products covered are inverter output chokes to be connected between an AC drive and an AC motor to reduce voltage harmonics.
3. Appropriate cooling measures shall be taken based on the power loss data within the instructions available from the manufacturer.
4. Grounding means for cat.nos. SFB 230/72 and SFB 230/90 shall be completed by screw with hexagonal head, size M6, in the end-use.