

NOMENCLATURE:

See RATINGS table above.

CONDITIONS OF ACCEPTABILITY:

1. The products covered by this report are intended for use with Power Conversion Equipment (inverters) only.
- *2. Spacings at terminals were only evaluated according to UL840. The accordance with Canadian requirements has to be evaluated in the end use. (for B 0502050 through B **0502054**, **B 0810011**, and **B 0810012**).
3. Appropriate cooling measures shall be taken based on the power loss data within the instructions available from the manufacturer.
4. Deleted
5. External wiring material for models with bus bar screw connectors - R/C (AVLV2), rated 105°C min., suitable for applied voltage and current. If wiring material with a lower temperature rating is used, an additional temperature test at the wiring material has to be conducted in the end use.