

### **Condition of Acceptability -**

When installed in the final use equipment, etc., the following are among the considerations to be made:

1. The device shall be installed in compliance with the enclosure, mounting, spacing, and segregation requirements of the ultimate application.
2. These devices are intended to be factory installed, while the terminals on these devices are suitable for field wiring.
3. No portion of these devices was evaluated as providing an ultimate electrical enclosure. Therefore, if any part of the control is deemed as an ultimate enclosure during the appliance investigation, enclosure testing shall be conducted as part of the appliance investigation.
5. No portion of these devices, including the housing, should be user accessible after installation in end product. The enclosure is suitable for basic insulation only.