

## CONDITIONS OF ACCEPTABILITY-

1. The transformers are provided with a class 105 insulation system. The designated Reference number of the insulation system into the class is included in the markings.
2. The VA Ratings is based on the ambient temperature (ta) or less, shown in table 1, 2 and table 3 for these components when used in the end equipment. The designated ambient temperature is included in the markings.
3. These components have been judged on the basis of the required spacing in the Standard for Electronic Data Processing Equipment (UL 478) which covers a possible end-use product for which the component e.g. was intended.
- 4. Models VBN and VCN are only provided with a UL Class 130B insulation system (E216803)**