File E103521 Vol. 1 Sec. 3 Page 2 Issued: 1997-03-31 and Report Revised: 2005-05-19

CONDITIONS OF ACCEPTABILITY:

- 1. The transformers and reactors type ${\tt EI}$, ${\tt UI}$ and ${\tt 3UI}$ are provided with a
 - class 105 insulation system (core term code suffix A)

or

- class 130 insulation system (core term code suffix B)

or

- class 155 insulation system (core term code suffix F)

or

- class 180 insulation system (core term code suffix H1)

The transformer type B9904048 is provided with class 130 insulation system designated B1 (see table II) or B2 (see table III)