

TECHNICAL CONSIDERATIONS (NOT FOR FIELD REPRESENTATIVE USE):

Conditions of Acceptability -

For use only in (or with) complete equipment where the acceptability of the combination is determined by Underwriters Laboratories Inc.

1. These devices are a network of solid-state integrated circuits and electrical spacings within the device are not specified.
2. These devices are entirely electronic in nature and **have no means** for manual operation or reset. **Manual current selection settings (including button) and/or reset of signal-monitoring circuits may be employed.**
3. These devices are designed to trip within the curve characteristics provided by the manufacturer.
4. The terminals of these devices have been evaluated for field-wiring. The connection suitability shall be determined in accordance with the end use application.
5. These devices have not been subjected to Tests for Telecom applications and their suitability for connection to telecommunication networks with outside plant connections should be determined in the end-use.
6. These devices were evaluated with respect to continuous current operation at the current levels shown in the electrical ratings section of this report.
7. These devices are intended for use in load circuits of switch mode power supplies or transformers having an isolated secondary supplying 24 Vdc.
8. These devices were evaluated in an ambient indicate on page 1. Suitability for use in a higher ambient has not been determined.
9. The outputs of these devices are not intended to be interconnected.