

CONDITIONS OF ACCEPTABILITY:

1. Transformer may or may not be provided with a outerwrap. A suitable enclosure should be provided. The enclosure shall be constructed and marked in accordance with UL 1561.
2. Enclosure size and ventilation must be in accordance with transformer manufacturer's specifications, or additional heating and dielectric testing will need to be performed.
3. Grounding and bonding of the transformer shall be judged in accordance with end-use equipment Standard.
4. Transformers may or may not be provided with suitable terminal block. Suitability of connections to end product shall be judged in accordance with end-use equipment standard and meet spacings table on page 6, and the following connection considerations; wiring gauge, wire type, ampacity rating equivalent or higher than 125% of winding rated current.